



GOVT OF ASSAM  
OFFICE OF THE EXECUTIVE ENGINEER, P.W.D (B)  
SONITPUR DISTRICT TERRITORIAL BUILDING DIVISION

**CERTIFICATE OF FITNESS**

This is to certify that the building of “Maharshi Vidya mandir”, at Tezpur, Poruagaon Dist: Sonitpur, Assam has been physically verified by the competent officials of this division and have noticed that the following observations:

Building 1:

1. The School building is of Assam Type in nature.
2. Wall type- brickwork with cement plastered.
3. The floor of the building is pucca.
4. The roof of the building is GCI sheet with tubular truss.
5. The building has wooden doors and aluminium windows.
6. The building has sanitary and water supply facilities.
7. The electrification facilities are also there in the building.

Building 2:

1. The school building is a RCC(G+2) building
2. Wall type- brickwork with cement plastered.
3. Floor of the building is pucca.
4. Roof of the building is RCC slab.
5. The building has wooden doors and aluminium windows.
6. The building has sanitary and water supply facilities.
7. The electrification facilities are also there in the building.

There is a playground in front of these buildings.

In view of the above, it can be stated that the building is structurally fit for use under normal condition.

*N.B: The validity of the fitness of the building will be 1 (one) year from the date of issue of this fitness certificate.*

Executive Engineer, PWD  
Sonitpur District Territorial Building Division.  
Tezpur.

Memo No.: SBD/TB/Fitness/2025-26/ 464

Dtd. 22/5/2026

Copy to: The Principal, Maharshi Vidya Mandir, Tezpur PoruaGaon, Dist.-Sonitpur, Assam for favour of information.

Executive Engineer, PWD  
Sonitpur District Territorial Building Division.  
Tezpur.